



# NOTES:

1. MINIMUM DISTANCE FROM WALL TO METER IS 2'-0".
2. MINIMUM DISTANCE FROM METER TO BYPASS LINE IS 2'-6".
3. ALL VALVES TO BE NON RISING.
- \* 4. A CHECK VALVE IS REQUIRED IF NO BACKFLOW PREVENTION DEVICE IS INSTALLED.
5. PIPING FOR 3" CAN BE COPPER OR DUCTILE IRON, OVER 3" INSTALLATIONS MUST BE DUCTILE IRON ONLY.
6. SEE MS16 FOR APPROVED COMPOUND METER MANUFACTURERS.
7. INSIDE SETTING REQUIRES PRE-APPROVAL PRIOR TO INSTALLATION.
8. 3" THROUGH 6" COMPOUND METERS REQUIRE AN ELECTRONIC DIGITAL ENCODER OR MECHANICALLY ENCODED REGISTER WITH AN ITRON ERT MODEL 40W FOR EACH REGISTER.

## DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204  
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

## INSIDE SETTING FOR 3" AND LARGER COMPOUND METER

Scale:   NONE   Date:   DECEMBER     1998  

Drawn:   C.B.B.   Tr:        Ck:       

Approved:        Dr.   127   No.   35